



Report No. 392-2015-00215801B

Eurofins Product Testing A/S Smedeskovvej 38 8464 Galten Denmark

voc@eurofins.com www.eurofins.com/voc-testing

Date 26 August 2015

Hunter Douglas Europe BV Piekstraat 2 3071 EL Rotterdam NETHERLANDS

VOC Emission Test report

1. Sample Information

Sample identification	Hunter Douglas Felt Linear
Product type	Ceiling panel
Batch no.	V4560/3+002/00
Production date	15 May 2015
Date when sample was received	13/07/2015
Testing (start - end)	22/07/2015 - 19/08/2015

2. Resulting VOC Emission Class Label

This recommendation is based on French regulation of March 23, 2011 (décret DEVL1101903D) and of April 19, 2011 (arrêté DEVL1104875A). For details please see www.eurofins.com/france-voc



Information sur le niveau d'émission de substances volatiles dans l'air intérieur, présentant un risque de toxicité par inhalation, sur une écheile de classe allant de A+ (très faibles émissions) à C (fortes émissions).

The product was assigned a VOC emission class without taking into account the measurement uncertainty associated with the result. As specified in French Decree no. 2011-321 of March 23, 2011, correct assignment of the VOC emission class is the sole responsibility of the party responsible for distribution of the product in the French market.

3. Conclusion on CMR emissions

The tested product fulfills the requirements of the French regulation DEVP0908633A of 30 April 2009 and DEVP0910046A of 28 May 2009. For details please see www.eurofins.com/france-voc.



4. Test Method

Method	od Principle Paramete		neter	Quantification limit	Uncertainty					
ISO 16000 parts -3, -6, -9, -11		GC/MS	VOC		2 µg/m³					
Internal method numbers: 9810, 9811, 9812, 2808B, 8400		HPLC/UV	Volatile alde- hydes		3 µg/m³	22% (RSD)				
ISO 16000 parts -3, -6, -9	-9, -11 GC/MS 4CMR		MR	<1 µg/m³	Um = 2 x					
Internal method numbers: 9811, 9812, 2808B, 8400,	9810, 2616					RSD=45 %				
Test chamber parameter										
Chamber volume, I	119	Temperature, °C		23±1	Relative humidity, %		50±3			
Air change rate, 1/h	0.5	Loading ratio, m ² /m ³		1.4 *						
Test condition: Sample stayed in test chamber during the whole 28 days testing period.										
Sample preparation										
The sample was transferred directly into the chamber.										
* The results have been recalculated to a loading factor of 0.4m ² /m ³ .										





5. Results

	Concentration after 28 days µg/m³	С	В	A	A+			
TVOC	< 2	>2000	<2000	<1500	<1000			
Formaldehyde	< 3	>120	<120	<60	<10			
Acetaldehyde	< 3	>400	<400	<300	<200			
Toluene	< 2	>600	<600	<450	<300			
Tetrachloroethylene	< 2	>500	<500	<350	<250			
Ethylbenzene	< 2	>1500	<1500	<1000	<750			
Xylene	< 2	>400	<400	<300	<200			
Styrene	< 2	>500	<500	<350	<250			
2-Butoxyethanol	< 2	>2000	<2000	<1500	<1000			
1,2,4-Trimethylbenzene	< 2	>2000	<2000	<1500	<1000			
1,4-Dichlorobenzene	< 2	>120	<120	<90	<60			
CMR compounds		Maximum allowed air concentration						
Benzene	< 1	<1						
Trichloroethylene	< 1	<1						
Dibutylphthalate (DBP)*	< 1	<1						
Diethylhexylphthalate (DEHP) *	< 1	<1						

< Means less than

Means higher than
Not a part of our ac

* Not a part of our accreditation (EN ISO/IEC 17025:2005) by DANAK (no. 522))

80

Thomas Bjerring Analytical Service Manager

Mariafelle

Maria Pelle Chemist